


OFFICE OF THE PRINCIPAL, ISPAT AUTONOMOUS COLLEGE, ROURKELA

No:- 899 / 11CR / 24 / Date 26.04.2024

QUOTATION CALL NOTICE

Sealed quotations on plain paper/letterhead are invited from firms located in Odisha, possessing a valid PAN card and GSTIN, for the replacement of damaged electrical items by the new ones subject to the requirement of Load along with the replacement of AB switch near the transformer. Firms must submit their quotations with specifications for the respective items after visiting the worksite to the undersigned on or before 03.05.2024 by 10:00 AM. The quotations will be opened at 11:30 AM on the same date in the presence of the quoting firms. The undersigned reserves the right to reject any or all quotations without assigning any reason thereof. The detailed specifications are attached in Annexure-1.


Principal
Ispat Autonomous College
Sector-16, Rourkela

Copy to – Purchase File / College Notice Board and Website for publication.

Replacement of damaged electrical items by the new ones subject to the requirement of Load along with the replacement of AB switch near the transformer at Ispat Autonomous College,Rourkela.

Annexure-I

SL NO	ITEM	QUANTITY	UNIT	RATE	GST	Total Amount
1	Supplying and fixing of following ways surface/recess mounting,vertical type,415 volts, TPN MCB distribution board of sheet steel, dust protected , duly powder painted, inclusive of 200 amps tinned copper bus bar , common neutral link ,earth bar,din bar for mounting MCB's (but without MCB's and incomer)as required . (not vertical type MCB TPDB is normally used where 3 phase outlets are required) 6 way (12+18)Double door, MAKE:-SCHNEIDER ACT19	2.00	NOS			
2	Supplying and fixing 5 amps to 32 amps rating 240/415 volts , "C" curve,miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connection, testing and commissioning etc.as required.DOUBLE POOL (MAKE:-SCHNEIDER ACT19)	45.00	NOS			
3	Supplying and fixing following rating , four pole , 415 volts , isolator in the existing MCB DB complete with connections, testing and commissioning etc.as required. 63 AMP 4 POLE (MAKE:-SCHNEIDER ACT19)	2.00	NOS			
4	Supplying and fixing 40 amps to 63 amps rating ,240/415 volts,"C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections , testing and commissioning etc. as required .DOUBLE POOL (MAKE:-SCHNEIDER ACT19)	4.00	NOS			
5	Supply and making end termination with steel compression gland and aluminium lugs for following size of pvc insulated and pvc sheathed/xlpe alu conductor cable 1.1 kc grade as required	2.00	NOS			
6	Earthing with G.I pipe 3 mtr long 40 mm dia including accessories and providing masonary enclosure with bentonite powder as required .	2.00	NOS			
7	Supply and erection of 11 kv 400 amp 25 ka/1 sec centre rotating double break isolator without earth switch with copper pipe in middle.	1.00	NOS			
8	Supply and erection of single piece nonliner resistor type lighting arrestor suitable for 3 wire , 11 kv overhead lines with rated voltage 11 kv (rms)	3.00	NOS			
9	Providing the fixing 25mm x 3mm G.I strip on surface or in recess for connection etc.	35.00	MTR			

(Signature)
26-04-24

Principal
Ispat Autonomous College
Sector-16, Rourkela